

APPENDIX A

Direct Reading Environmental Measurements from August 20th & 21st, 2020

Direct Reading Environmental Measurements – Test Round 1 obtained by two different Technicians on August 20th, 2020 between 1245 and 1357 hours from within Somerset Berkley High School. Test Rounds 2 & 3 obtained by two different Technicians on August 21st, 2020 between 0827 and 1013 hours from within Somerset Berkley High School.

LOCATION	TEST Round	Time (EDT)	RH (%)	Temp (Deg F)	H2S (ppm)	LEL (%)	CO (ppm)	O (%)	VOC (ppm)
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Classroom 313	1	1251	44	73	0	0	0	20.9	0
Classroom 316	1	1254	45	73	0	0	0	20.9	0
Classroom 323	1	1256	44	73	0	0	0	20.9	0
Classroom 322	1	1258	45	73	0	0	0	20.9	0
Classroom 328	1	1300	45	73	0	0	0	20.9	0
Classroom 225	1	1306	48	73	0	0	0	20.9	0
Classroom 221	1	1308	48	73	0	0	0	20.9	0
Classroom 216	1	1310	48	73	0	0	0	20.9	0
Classroom 211	1	1311	48	73	0	0	0	20.9	0
TV Studio	1	1314	47	73	0	0	0	20.9	0
Classroom 115	1	1316	48	73	0	0	0	20.9	0
Classroom 114	1	1318	50	72	0	0	0	20.9	0
Classroom 109	1	1320	50	72	0	0	0	20.9	0
Administration	1	1322	51	72	0	0	0	20.9	0
Library	1	1324	53	72	0	0	0	20.9	0
Nurse Office	1	1326	54	72	0	0	0	20.9	0
Classroom 141	1	1328	52	72	0	0	0	20.9	0
Classroom 127	1	1331	51	73	0	0	0	20.9	0
Classroom 124	1	1333	50	73	0	0	0	20.9	0
Classroom 121	1	1335	51	72	0	0	0	20.9	0
Classroom 310A	1	1245	-	-	0	0	0	20.9	0
Classroom 305	1	1247	-	-	0	0	0	20.9	0
Classroom 336	1	1251	-	-	0	0	0	20.9	0
Classroom 333	1	1252	-	-	0	0	0	20.9	0
Classroom 341	1	1254	-	-	0	0	0	20.9	0
Classroom 301	1	1256	-	-	0	0	0	20.9	0
Classroom 210A	1	1259	-	-	0	0	0	20.9	0

Classroom 205	1	1303	-	-	0	0	0	20.9	0
Classroom 236	1	1306	-	-	0	0	0	20.9	0
Classroom 233	1	1309	-	-	0	0	0	20.9	0
Classroom 229	1	1311	-	-	0	0	0	20.9	0
Gymnasium	1	1314	-	-	0	0	0	20.9	0
Boys Locker Room	1	1320	-	-	0	0	0	20.9	0
Girls Locker Room	1	1324	-	-	0	0	0	20.9	0
Arts Center	1	1327	-	-	0	0	0	20.9	0
Kitchen	1	1331	-	-	0	0	0	20.9	0
Cafeteria	1	1335	-	-	0	0	0	20.9	0
Classroom 131	1	1338	-	-	0	0	0	20.9	0
Classroom 143	1	1342	-	-	0	0	0	20.9	0
Classroom 135	1	1350	-	-	0	0	0	20.9	0
Gymnasium #2	1	1354	-	-	0	0	0	20.9	0
Outside	1	1357	-	-	0	0	0	20.9	0
Classroom 313	2	0832	-	-	0	0	0	20.9	0
Classroom 316	2	0834	-	-	0	0	0	20.9	0
Classroom 323	2	0835	-	-	0	0	0	20.9	0
Classroom 322	2	0836	-	-	0	0	0	20.9	0
Classroom 328	2	0838	-	-	0	0	0	20.9	0
Classroom 225	2	0843	-	-	0	0	0	20.9	0
Classroom 221	2	0845	-	-	0	0	0	20.9	0
Classroom 216	2	0846	-	-	0	0	0	20.9	0
Classroom 211	2	0847	-	-	0	0	0	20.9	0
TV Studio	2	0900	-	-	0	0	0	20.9	0
Classroom 115	2	0856	-	-	0	0	0	20.9	0
Classroom 114	2	0857	-	-	0	0	0	20.9	0
Classroom 109	2	0858	-	-	0	0	0	20.9	0
Administration	2	0906	-	-	0	0	0	20.9	0
Library	2	0904	-	-	0	0	0	20.9	0
Nurse Office	2	0902	-	-	0	0	0	20.9	0
Classroom 141	2	0907	-	-	0	0	0	20.9	0
Classroom 127	2	0910	-	-	0	0	0	20.9	0
Classroom 124	2	0911	-	-	0	0	0	20.9	0
Classroom 121	2	0912	-	-	0	0	0	20.9	0

Classroom 310A	2	0827	58	70	0	0	0	20.9	0
Classroom 305	2	0829	58	70	0	0	0	20.9	0
Classroom 336	2	0831	58	70	0	0	0	20.9	0
Classroom 333	2	0834	58	70	0	0	0	20.9	0
Classroom 341	2	0837	58	71	0	0	0	20.9	0
Classroom 301	2	0839	58	70	0	0	0	20.9	0
Classroom 210A	2	0842	55	73	0	0	0	20.9	0
Classroom 205	2	0845	55	72	0	0	0	20.9	0
Classroom 236	2	0847	55	71	0	0	0	20.9	0
Classroom 233	2	0849	55	70	0	0	0	20.9	0
Classroom 229	2	0851	55	70	0	0	0	20.9	0
Gymnasium	2	0853	55	70	0	0	0	20.9	0
Gymnasium #2	2	0857	56	70	0	0	0	20.9	0
Boys Locker Room	2	0859	55	70	0	0	0	20.9	0
Girls Locker Room	2	0905	55	70	0	0	0	20.9	0
Arts Center	2	0907	55	70	0	0	0	20.9	0
Kitchen	2	0906	55	70	0	0	0	20.9	0
Cafeteria	2	0908	56	70	0	0	0	20.9	0
Classroom 131	2	0911	56	70	0	0	0	20.9	0
Classroom 135	2	0914	55	70	0	0	0	20.9	0
Outside	2	0918	54	70	0	0	0	20.9	0
Classroom 313	3	0917	60	70	0	0	0	20.9	0
Classroom 316	3	0919	60	70	0	0	0	20.9	0
Classroom 323	3	0921	59	70	0	0	0	20.9	0
Classroom 322	3	0923	59	70	0	0	0	20.9	0
Classroom 328	3	0925	59	70	0	0	0	20.9	0
Classroom 225	3	0927	61	70	0	0	0	20.9	0
Classroom 221	3	0930	64	70	0	0	0	20.9	0
Classroom 216	3	0935	64	70	0	0	0	20.9	0
Classroom 211	3	0937	63	70	0	0	0	20.9	0
TV Studio	3	0939	65	70	0	0	0	20.9	0
Classroom 115	3	0941	63	70	0	0	0	20.9	0
Classroom 114	3	0943	63	70	0	0	0	20.9	0
Classroom 109	3	0946	62	70	0	0	0	20.9	0
Administration	3	0948	62	70	0	0	0	20.9	0
Library	3	0950	63	70	0	0	0	20.9	0

Nurse Office	3	0957	61	70	0	0	0	20.9	0
Classroom 141	3	0959	62	70	0	0	0	20.9	0
Classroom 127	3	1001	63	70	0	0	0	20.9	0
Classroom 124	3	1003	63	70	0	0	0	20.9	0
Classroom 121	3	1005	62	70	0	0	0	20.9	0
Classroom 310A	3	0925	-	-	0	0	0	20.9	0
Classroom 305	3	0927	-	-	0	0	0	20.9	0
Classroom 336	3	0930	-	-	0	0	0	20.9	0
Classroom 333	3	0931	-	-	0	0	0	20.9	0
Classroom 341	3	0934	-	-	0	0	0	20.9	0
Classroom 301	3	0937	-	-	0	0	0	20.9	0
Classroom 210A	3	0939	-	-	0	0	0	20.9	0
Classroom 205	3	0941	-	-	0	0	0	20.9	0
Classroom 236	3	0943	-	-	0	0	0	20.9	0
Classroom 233	3	0946	-	-	0	0	0	20.9	0
Classroom 229	3	0948	-	-	0	0	0	20.9	0
Gymnasium	3	0953	-	-	0	0	0	20.9	0
Gymnasium #2	3	0955	-	-	0	0	0	20.9	0
Boys Locker Room	3	0957	-	-	0	0	0	20.9	0
Girls Locker Room	3	0959	-	-	0	0	0	20.9	0
Arts Center	3	1002	-	-	0	0	0	20.9	0
Kitchen	3	1003	-	-	0	0	0	20.9	0
Cafeteria	3	1005	-	-	0	0	0	20.9	0
Classroom 131	3	1006	-	-	0	0	0	20.9	0
Classroom 135	3	1008	-	-	0	0	0	20.9	0
Outside	3	1013	-	-	0	0	0	20.9	0

APPENDIX B

Mold Laboratory Analytical Results