

## **APPENDIX A**

**Direct Reading Environmental Measurements from August 2<sup>nd</sup>, 2021**

**Direct Reading Environmental Measurements – Obtained by two different  
Environmental Technicians on August 2<sup>nd</sup>, 2021 between 1100 and 1457 hours from  
within the South Elementary School.**

<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
<b>ACCEPTABLE LIMIT</b>			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Cafeteria	1	1100	-	-	0	0	0	20.9	0
Outside	1	1102	-	-	0	0	0	20.9	0
Locker Room Storage	1	1103	-	-	0	0	0	20.9	0
Room 3	1	1104	-	-	0	0	0	20.9	0
Room 5	1	1106	-	-	0	0	0	20.9	0
Room 7	1	1107	-	-	0	0	0	20.9	0
Girls Bathroom Across from Room 1	1	1109	-	-	0	0	0	20.9	0
Boys Bathroom Across from Room 1	1	1110	-	-	0	0	0	20.9	0
Teachers Room	1	1111	-	-	0	0	0	20.9	0
Main Office	1	1112	-	-	0	0	0	20.9	0
Room 2	1	1113	-	-	0	0	0	20.9	0
Room 9	1	1114	-	-	0	0	0	20.9	0
Maintenance Storage	1	1118	-	-	0	0	0	20.9	0
Girls Bathroom (Hot / Cold Hall)	1	1119	-	-	0	0	0	20.9	0
Room 11	1	1120	-	-	0	0	0	20.9	0
Room 12	1	1121	-	-	0	0	0	20.9	0
Room 13	1	1122	-	-	0	0	0	20.9	0
Room 14	1	1123	-	-	0	0	0	20.9	0
School Adjustment	1	1124	-	-	0	0	0	20.9	0
Girls Bathroom (Read Hall)	1	1125	-	-	0	0	0	20.9	0
Technology	1	1126	-	-	0	0	0	20.9	0

<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Cafeteria	2	1127	-	-	0	0	0	20.9	0
Outside	2	1130	-	-	0	0	0	20.9	0
Locker Room Storage	2	1131	-	-	0	0	0	20.9	0
Room 3	2	1132	-	-	0	0	0	20.9	0
Room 5	2	1133	-	-	0	0	0	20.9	0
Room 7	2	1134	-	-	0	0	0	20.9	0
Girls Bathroom Across from Room 1	2	1135	-	-	0	0	0	20.9	0
Boys Bathroom Across from Room 1	2	1137	-	-	0	0	0	20.9	0
Teachers Room	2	1138	-	-	0	0	0	20.9	0
Main Office	2	1140	-	-	0	0	0	20.9	0
Room 2	2	1145	-	-	0	0	0	20.9	0
Room 9	2	1146	-	-	0	0	0	20.9	0
Maintenance Storage	2	1147	-	-	0	0	0	20.9	0
Girls Bathroom (Hot / Cold Hall)	2	1147	-	-	0	0	0	20.9	0
Room 11	2	1148	-	-	0	0	0	20.9	0
Room 12	2	1150	-	-	0	0	0	20.9	0
Room 13	2	1151	-	-	0	0	0	20.9	0
Room 14	2	1153	-	-	0	0	0	20.9	0
School Adjustment	2	1154	-	-	0	0	0	20.9	0
Girls Bathroom (Read Hall)	2	1155	-	-	0	0	0	20.9	0
Technology	2	1156	-	-	0	0	0	20.9	0
<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Cafeteria	3	1340	-	-	0	0	0	20.9	0

Outside	3	1342	-	-	0	0	0	20.9	0
Locker Room Storage	3	1343	-	-	0	0	0	20.9	0
Room 3	3	1345	-	-	0	0	0	20.9	0
Room 5	3	1347	-	-	0	0	0	20.9	0
Room 7	3	1349	-	-	0	0	0	20.9	0
Girls Bathroom Across from Room 1	3	1352	-	-	0	0	0	20.9	0
Boys Bathroom Across from Room 1	3	1354	-	-	0	0	0	20.9	0
Teachers Room	3	1402	-	-	0	0	0	20.9	0
Main Office	3	1403	-	-	0	0	0	20.9	0
Room 2	3	1405	-	-	0	0	0	20.9	0
Room 9	3	1407	-	-	0	0	0	20.9	0
Maintenance Storage	3	1408	-	-	0	0	0	20.9	0
Room 11	3	1411	-	-	0	0	0	20.9	0
Room 13	3	1412	-	-	0	0	0	20.9	0
Room 14	3	1415	-	-	0	0	0	20.9	0
School Adjustment	3	1417	-	-	0	0	0	20.9	0
Technology	3	1421	-	-	0	0	0	20.9	0
<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Cafeteria	4	1425	-	-	0	0	0	20.9	0
Outside	4	1427	-	-	0	0	0	20.9	0
Locker Room Storage	4	1429	-	-	0	0	0	20.9	0
Room 3	4	1432	-	-	0	0	0	20.9	0
Room 5	4	1434	-	-	0	0	0	20.9	0
Room 7	4	1437	-	-	0	0	0	20.9	0
Girls Bathroom Across from Room 1	4	1439	-	-	0	0	0	20.9	0

Boys Bathroom Across from Room 1	4	1442	-	-	0	0	0	20.9	0
Teachers Room	4	1445	-	-	0	0	0	20.9	0
Main Office	4	1446	-	-	0	0	0	20.9	0
Room 2	4	1447	-	-	0	0	0	20.9	0
Room 9	4	1449	-	-	0	0	0	20.9	0
Maintenance Storage	4	1451	-	-	0	0	0	20.9	0
Room 11	4	1452	-	-	0	0	0	20.9	0
Room 13	4	1453	-	-	0	0	0	20.9	0
Room 14	4	1454	-	-	0	0	0	20.9	0
School Adjustment	4	1455	-	-	0	0	0	20.9	0
Technology	4	1457	-	-	0	0	0	20.9	0

## **APPENDIX B**

### **Mold Laboratory Analytical Results**