

APPENDIX A

**Direct Reading Environmental Measurements at the Middle School from
August 19th, 2020**

Direct Reading Environmental Measurements – Obtained by two different Technicians on August 19th, 2020 between 0826 and 1041 hours from within Somerset Middle School.

LOCATION	TEST Round	Time (EDT)	RH (%)	Temp (Deg F)	H2S (ppm)	LEL (%)	CO (ppm)	O (%)	VOC (ppm)
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Room 30	1	0826	-	-	0	0	0	20.9	0
Room 17	1	0828	-	-	0	0	0	20.9	0
Room 15	1	0831	-	-	0	0	0	20.9	0
Room 13A	1	0834	-	-	0	0	0	20.9	0
Room 12	1	0836	-	-	0	0	0	20.9	0
Room 11	1	0839	-	-	0	0	0	20.9	0
Room 9	1	0841	-	-	0	0	0	20.9	0
Gymnasium	1	0845	-	-	0	0	0	20.9	0
Room 62	1	0847	-	-	0	0	0	20.9	0
Room 58	1	0850	-	-	0	0	0	20.9	0
Room 56	1	0852	-	-	0	0	0	20.9	0
Room 53	1	0854	-	-	0	0	0	20.9	0
Room 48	1	0857	-	-	0	0	0	20.9	0
Room 46	1	0900	-	-	0	0	0	20.9	0
Music Room	1	0905	-	-	0	0	0	20.9	0
Art Room 1	1	0907	-	-	0	0	0	20.9	0
Outdoors	1	0910	-	-	0	0	0	20.9	0
Garage	1	0831	61	70	0	0	0	20.9	0.1
Room 36	1	0837	61	72	0	0	0	20.9	0
Room 34	1	0839	61	72	0	0	0	20.9	0.1
Room 32	1	0841	61	72	0	0	0	20.9	0
Tech Room B	1	0848	61	72	0	0	0	20.9	0
Library Office	1	0849	61	72	0	0	0	20.9	0
Library	1	0850	61	72	0	0	0	20.9	0
Custodian	1	0852	61	72	0	0	0	20.9	0
Nurse	1	0854	61	72	0	0	0	20.9	0
Main Office/Conference Room	1	0859	62	72	0	0	0	20.9	0

Room 8/Principals	1	0904	62	72	0	0	0	20.9	0
Room 6	1	0906	60	73	0	0	0	20.9	0
Room 4	1	0907	60	73	0	0	0	20.9	0
South Coast 2	1	0911	57	75	0	0	0	20.9	0
Tech Computer Lab 43	1	0914	55	75	0	0	0	20.9	0
Auditorium	1	0917	55	73	0	0	0	20.9	0
Tech Lab 41	1	0920	55	73	0	0	0	20.9	0
Lecture Room	1	0922	55	73	0	0	0	20.9	0
Teacher Dining	1	0924	55	73	0	0	0	20.9	0
Cafeteria	1	0925	55	73	0	0	0	20.9	0
Guidance Office	1	0901	62	72	0	0	0	20.9	0
Room 30	2	0914	-	-	0	0	0	20.9	0
Room 17	2	0916	-	-	0	0	0	20.9	0
Room 15	2	0918	-	-	0	0	0	20.9	0
Room 13A	2	0920	-	-	0	0	0	20.9	0
Room 12	2	0923	-	-	0	0	0	20.9	0
Room 11	2	0925	-	-	0	0	0	20.9	0
Room 9	2	0927	-	-	0	0	0	20.9	0
Gymnasium	2	0929	-	-	0	0	0	20.9	0
Room 62	2	0931	-	-	0	0	0	20.9	0
Room 58	2	0934	-	-	0	0	0	20.9	0
Room 56	2	0937	-	-	0	0	0	20.9	0
Room 53	2	0939	-	-	0	0	0	20.9	0
Room 48	2	0941	-	-	0	0	0	20.9	0
Room 46	2	0943	-	-	0	0	0	20.9	0
Music Room	2	0947	-	-	0	0	0	20.9	0
Art Room 1	2	0950	-	-	0	0	0	20.9	0
Outdoors	2	0954	-	-	0	0	0	20.9	0
Garage	2	0929	53	73	0	0	0	20.9	0
Room 36	2	0933	53	73	0	0	0	20.9	0
Room 34	2	0937	53	73	0	0	0	20.9	0.1
Room 32	2	0938	54	73	0	0	0	20.9	0
Tech Room B	2	0940	54	73	0	0	0	20.9	0
Library Office	2	0941	55	73	0	0	0	20.9	0
Library	2	0942	55	73	0	0	0	20.9	0

Custodian	2	0944	55	73	0	0	0	20.9	0
Nurse	2	0946	55	73	0	0	0	20.9	0
Main Office/Conference Room	2	0948	56	73	0	0	0	20.9	0
Room 8/Principals	2	0951	57	73	0	0	0	20.9	0
Room 6	2	0953	58	73	0	0	0	20.9	0
Room 4	2	0956	57	75	0	0	0	20.9	0
South Coast 2	2	0957	56	75	0	0	0	20.9	0
Tech Computer Lab 43	2	1009	-	-	0	0	0	20.9	0
Auditorium	2	1010	-	-	0	0	0	20.9	0
Tech Lab 41	2	1012	56	73	0	0	0	20.9	0
Lecture Room	2	1014	-	-	0	0	0	20.9	0
Teacher Dining	2	1015	-	-	0	0	0	20.9	0
Cafeteria	2	1016	-	-	0	0	0	20.9	0
Guidance Office	2	0950	56	73	0	0	0	20.9	0
Room 30	3	1007	54	75	0	0	0	20.9	0
Room 17	3	1009	56	75	0	0	0	20.9	0
Room 15	3	1011	55	75	0	0	0	20.9	0
Room 13A	3	1012	54	75	0	0	0	20.9	0
Room 12	3	1013	54	75	0	0	0	20.9	0
Room 11	3	1015	54	75	0	0	0	20.9	1
Room 9	3	1017	54	75	0	0	0	20.9	0
Gymnasium	3	1019	54	75	0	0	0	20.9	0
Room 62	3	1021	54	75	0	0	0	20.9	0
Room 58	3	1024	54	75	0	0	0	20.9	0
Room 56	3	1027	56	75	0	0	0	20.9	0
Room 53	3	1029	54	75	0	0	0	20.9	0
Room 48	3	1032	54	75	0	0	0	20.9	0
Room 46	3	1034	54	75	0	0	0	20.9	0
Music Room	3	1036	54	75	0	0	0	20.9	0
Art Room 1	3	1039	54	75	0	0	0	20.9	0
Outdoors	3	1041	56	85	0	0	0	20.9	0
Garage	3	1019	-	-	0	0	0	20.9	0
Room 36	3	1020	-	-	0	0	0	20.9	0
Room 34	3	1021	-	-	0	0	0	20.9	0

Room 32	3	1021	-	-	0	0	0	20.9	0
Tech Room B	3	1023	-	-	0	0	0	20.9	0
Library Office	3	1024	-	-	0	0	0	20.9	0
Library	3	1025	-	-	0	0	0	20.9	0
Custodian	3	1026	-	-	0	0	0	20.9	0
Nurse	3	1027	-	-	0	0	0	20.9	0
Main Office/Conference Room	3	1028	-	-	0	0	0	20.9	0
Room 8/Principals	3	1029	-	-	0	0	0	20.9	0
Room 6	3	1031	-	-	0	0	0	20.9	0
Room 4	3	1032	-	-	0	0	0	20.9	0
South Coast 2	3	1033	-	-	0	0	0	20.9	0
Tech Computer Lab 43	3	1034	-	-	0	0	0	20.9	0
Auditorium	3	1035	-	-	0	0	0	20.9	0
Tech Lab 41	3	1036	-	-	0	0	0	20.9	0
Lecture Room	3	1037	-	-	0	0	0	20.9	0
Teacher Dining	3	1038	-	-	0	0	0	20.9	0
Cafeteria	3	1039	-	-	0	0	0	20.9	0
Guidance Office	3	1030	-	-	0	0	0	20.9	0

APPENDIX B

Mold Laboratory Analytical Results