

**APPENDIX A**

**Direct Reading Environmental Measurements from August 19<sup>th</sup> & 20<sup>th</sup>, 2020  
at the North Elementary School**

**Direct Reading Environmental Measurements – Test Rounds 1 & 2 obtained by two different Technicians on August 19<sup>th</sup>, 2020 between 1348 and 1450 hours from within North Elementary School. Test Round 3 obtained by two different Technicians on August 20<sup>st</sup>, 2020 between 0818 and 0851 hours from within North Elementary School.**

<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Cafeteria	1	1358	-	-	0	0	0	20.9	0
Kitchen Work Area	1	1402	-	-	0	0	0	20.9	0
Laundry Room Area	1	1403	-	-	0	0	0	20.9	0
Food Storage	1	1405	-	-	0	0	0	20.9	0
Boys Bathroom	1	1410	-	-	0	0	0	20.9	0
Preschool Speech Room	1	1413	-	-	0	0	0	20.9	0
Preschool/ Kindergarten #2	1	1415	-	-	0	0	0	20.9	0
Preschool/ Kindergarten #3	1	1417	-	-	0	0	0	20.9	0
Conference Room	1	1418	-	-	0	0	0	20.9	0
Garage	1	1421	-	-	0	0	0	20.9	0
Top Floor Gym	1	1420	-	-	0	0	0	20.9	0
Open Area “G”	1	1422	-	-	0	0	0	20.9	0
Open Area “H”	1	1424	-	-	0	0	0	20.9	0
Library	1	1426	-	-	0	0	0	20.9	0
Open Area “A”	1	1429	-	-	0	0	0	20.9	0
Open Area “B”	1	1431	-	-	0	0	0	20.9	0
Main Office	1	1433	-	-	0	0	0	20.9	0
Speech and Specials	1	1437	-	-	0	0	0	20.9	0
Open Area “C”	1	1439	-	-	0	0	0	20.9	0
Open Area “F”	1	1442	-	-	0	0	0	20.9	0
Open Area “E”	1	1444	-	-	0	0	0	20.9	0
Outdoors	1	1450	-	-	0	0	0	20.9	0
Cafeteria Adjacent Stairs	2	1427	-	-	0	0	0	20.9	0
Cafeteria Entrance from E15	2	1429	-	-	0	0	0	20.9	0

Kitchen Work Area	2	1430	-	-	0	0	0	20.9	0
Laundry Area	2	1432	-	-	0	0	0	20.9	0
Food Storage	2	1433	-	-	0	0	0	20.9	0
Boys Bathroom	2	1434	-	-	0	0	0	20.9	0
Preschool Speech Room	2	1435	-	-	0	0	0	20.9	0
Preschool/ Kindergarten #2	2	1436	-	-	0	0	0	20.9	0
Preschool/ Kindergarten #3	2	1437	-	-	0	0	0	20.9	0
Conference Room	2	1438	-	-	0	0	0	20.9	0
Garage	2	1439	-	-	0	0	0	20.9	0
Outside Garage	2	1440	-	-	0	0	0	20.9	0
Top Floor Gym	2	1348	-	-	0	0	0	20.9	0
Open Area "G"	2	1350	-	-	0	0	0	20.9	0
Open Area "H"	2	1352	-	-	0	0	0	20.9	0
Library	2	1354	-	-	0	0	0	20.9	0
Open Area "A"	2	1356	-	-	0	0	0	20.9	0
Open Area "B"	2	1358	-	-	0	0	0	20.9	0
Main Office	2	1401	-	-	0	0	0	20.9	0
Speech and Specials	2	1403	-	-	0	0	0	20.9	0
Open Area "C"	2	1405	-	-	0	0	0	20.9	0
Open Area "F"	2	1407	-	-	0	0	0	20.9	0
Open Area "E"	2	1409	-	-	0	0	0	20.9	0
Outdoors	2	1402	-	-	0	0	0	20.9	0
Cafeteria Adjacent Stairs	3	0818	-	-	0	0	0	20.9	0
Cafeteria Entrance from E15	3	0820	-	-	0	0	0	20.9	0
Kitchen Work Area	3	0825	-	-	0	0	0	20.9	0
Laundry Area	3	0827	-	-	0	0	0	20.9	0
Food Storage	3	0828	-	-	0	0	0	20.9	0
Boys Bathroom	3	0829	-	-	0	0	0	20.9	1
Preschool Speech Room	3	0830	-	-	0	0	0	20.9	0
Preschool/ Kindergarten #2	3	0831	-	-	0	0	0	20.9	0
Preschool/ Kindergarten #3	3	0832	-	-	0	0	0	20.9	0
Conference Room	3	0833	-	-	0	0	0	20.9	0
Garage	3	0834	-	-	0	0	0	20.9	0

Outside Garage	3	0835	-	-	0	0	0	20.9	0
Top Floor Gym	3	0824	59	70	0	0	0	20.9	0
Open Area "G"	3	0826	59	70	0	0	0	20.9	0
Open Area "H"	3	0829	57	70	0	0	0	20.9	0
Library	3	0832	59	70	0	0	0	20.9	0
Open Area "A"	3	0834	59	70	0	0	0	20.9	0
Open Area "B"	3	0837	58	70	0	0	0	20.9	0
Main Office	3	0839	59	70	0	0	0	20.9	0
Speech and Specials	3	0841	59	70	0	0	0	20.9	0
Open Area "C"	3	0844	58	70	0	0	0	20.9	0
Open Area "F"	3	0846	59	70	0	0	0	20.9	0
Open Area "E"	3	0849	59	70	0	0	0	20.9	0
Outdoors	3	0851	56	72	0	0	0	20.9	0

## **APPENDIX B**

### **Mold Laboratory Analytical Results**