

**APPENDIX A**

**Direct Reading Environmental Measurements from August 5, 2021**

**Direct Reading Environmental Measurements – Obtained by a technician on August 5<sup>th</sup>, 2021 between 1358 and 1610 hours from within Somerset Berkley High School.**

<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
<b>ACCEPTABLE LIMIT</b>			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Classroom 304A	1	1358	-	-	0	0	0	20.9	0
Classroom 305	1	-	-	-	0	0	0	20.9	0
Classroom 301	1	-	-	-	0	0	0	20.9	0
Classroom 308	1	-	-	-	0	0	0	20.9	0
Classroom 310A	1	-	-	-	0	0	0	20.9	0
Classroom 313	1	-	-	-	0	0	0	20.9	0
Classroom 314	1	-	-	-	0	0	0	20.9	0
Classroom 317	1	-	-	-	0	0	0	20.9	0
Classroom 320	1	-	-	-	0	0	0	20.9	0
Classroom 323	1	-	-	-	0	0	0	20.9	0
Classroom 327	1	-	-	-	0	0	0	20.9	0
T307 Area	1	-	-	-	0	0	0	20.9	0
Classroom 333	1	-	-	-	0	0	0	20.9	0
Classroom 336	1	-	-	-	0	0	0	20.9	0
Classroom 339	1	-	-	-	0	0	0	20.9	0
Classroom 341	1	-	-	-	0	0	0	20.9	0
Classroom 203A	1	-	-	-	0	0	0	20.9	0
Classroom 205	1	-	-	-	0	0	0	20.9	0
Classroom 210A	1	-	-	-	0	0	0	20.9	0
T204 Area	1	-	-	-	0	0	0	20.9	0
Classroom 204C	1	-	-	-	0	0	0	20.9	0
Classroom 204E	1	-	-	-	0	0	0	20.9	0
Classroom 238	1	-	-	-	0	0	0	20.9	0
Classroom 236	1	-	-	-	0	0	0	20.9	0
Classroom 235	1	-	-	-	0	0	0	20.9	0
Classroom 231	1	-	-	-	0	0	0	20.9	0
T208 Area	1	-	-	-	0	0	0	20.9	0
Classroom 221	1	-	-	-	0	0	0	20.9	0

Classroom 100L	1	-	-	-	0	0	0	20.9	0
Library North End	1	-	-	-	0	0	0	20.9	0
Library South End	1	-	-	-	0	0	0	20.9	0
Classroom 139	1	-	-	-	0	0	0	20.9	0
Hallway at E3	1	-	-	-	0	0	0	20.9	0
Workout room	1	-	-	-	0	0	0	20.9	0
Girls PE Room	1	-	-	-	0	0	0	20.9	0
Boys PE Room	1	-	-	-	0	0	0	20.9	0
Lobby at W10	1	-	-	-	0	0	0	20.9	0
Music Room 131A	1	-	-	-	0	0	0	20.9	0
Custodial room near track	1	-	-	-	0	0	0	20.9	0
Classroom 141	1	-	-	-	0	0	0	20.9	0
Classroom 138B	1	-	-	-	0	0	0	20.9	0
Classroom 102A	1	-	-	-	0	0	0	20.9	0
Classroom 105	1	-	-	-	0	0	0	20.9	0
Classroom 108	1	-	-	-	0	0	0	20.9	0
Classroom 114	1	-	-	-	0	0	0	20.9	0
Outdoors at the South side	1	-	-	-	0	0	0	20.9	0
Classroom 117D	1	-	-	-	0	0	0	20.9	0
Cafeteria East side	1	-	-	-	0	0	0	20.9	0
Cafeteria West side	1	-	-	-	0	0	0	20.9	0
<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Classroom 304A	2	-	-	-	0	0	0	20.9	0
Classroom 305	2	-	-	-	0	0	0	20.9	0
Classroom 301	2	-	-	-	0	0	0	20.9	0
Classroom 308	2	-	-	-	0	0	0	20.9	0
Classroom 310A	2	-	-	-	0	0	0	20.9	0
Classroom 313	2	-	-	-	0	0	0	20.9	0
Classroom 314	2	-	-	-	0	0	0	20.9	0
Classroom 317	2	-	-	-	0	0	0	20.9	0
Classroom 320	2	-	-	-	0	0	0	20.9	0

Classroom 323	2	-	-	-	0	0	0	20.9	0
Classroom 327	2	-	-	-	0	0	0	20.9	0
T307 Area	2	-	-	-	0	0	0	20.9	0
Classroom 333	2	-	-	-	0	0	0	20.9	0
Classroom 336	2	-	-	-	0	0	0	20.9	0
Classroom 339	2	-	-	-	0	0	0	20.9	0
Classroom 341	2	-	-	-	0	0	0	20.9	0
Classroom 203A	2	-	-	-	0	0	0	20.9	0
Classroom 205	2	-	-	-	0	0	0	20.9	0
Classroom 210A	2	-	-	-	0	0	0	20.9	0
T204 Area	2	-	-	-	0	0	0	20.9	0
Classroom 204C	2	-	-	-	0	0	0	20.9	0
Classroom 204E	2	-	-	-	0	0	0	20.9	0
Classroom 238	2	-	-	-	0	0	0	20.9	0
Classroom 236	2	-	-	-	0	0	0	20.9	0
Classroom 235	2	-	-	-	0	0	0	20.9	0
Classroom 231	2	-	-	-	0	0	0	20.9	0
T208 Area	2	-	-	-	0	0	0	20.9	0
Classroom 221	2	-	-	-	0	0	0	20.9	0
Classroom 100L	2	-	-	-	0	0	0	20.9	0
Library North End	2	-	-	-	0	0	0	20.9	0
Library South End	2	-	-	-	0	0	0	20.9	0
Classroom 139	2	-	-	-	0	0	0	20.9	0
Hallway at E3	2	-	-	-	0	0	0	20.9	0
Workout room	2	-	-	-	0	0	0	20.9	0
Girls PE Room	2	-	-	-	0	0	0	20.9	0
Boys PE Room	2	-	-	-	0	0	0	20.9	0
Lobby at W10	2	-	-	-	0	0	0	20.9	0
Music Room 131A	2	-	-	-	0	0	0	20.9	0
Custodial room near track	2	-	-	-	0	0	0	20.9	0
Classroom 141	2	-	-	-	0	0	0	20.9	0
Classroom 138B	2	-	-	-	0	0	0	20.9	0
Classroom 102A	2	-	-	-	0	0	0	20.9	0
Classroom 105	2	-	-	-	0	0	0	20.9	0
Classroom 108	2	-	-	-	0	0	0	20.9	0
Classroom 114	2	-	-	-	0	0	0	20.9	0

Outdoors at the South side	2	-	-	-	0	0	0	20.9	0
Classroom 117D	2	-	-	-	0	0	0	20.9	0
Cafeteria East side	2	-	-	-	0	0	0	20.9	0
Cafeteria West side	2	-	-	-	0	0	0	20.9	0
<b>LOCATION</b>	<b>TEST Round</b>	<b>Time (EDT)</b>	<b>RH (%)</b>	<b>Temp (Deg F)</b>	<b>H2S (ppm)</b>	<b>LEL (%)</b>	<b>CO (ppm)</b>	<b>O (%)</b>	<b>VOC (ppm)</b>
ACCEPTABLE LIMIT			<60	67 to 82	<20	<10%	<9	19.5 to 23.5	<100
Classroom 304A	3	-	-	-	0	0	0	20.9	0
Classroom 305	3	-	-	-	0	0	0	20.9	0
Classroom 301	3	-	-	-	0	0	0	20.9	0
Classroom 308	3	-	-	-	0	0	0	20.9	0
Classroom 310A	3	-	-	-	0	0	0	20.9	0
Classroom 313	3	-	-	-	0	0	0	20.9	0
Classroom 314	3	-	-	-	0	0	0	20.9	0
Classroom 317	3	-	-	-	0	0	0	20.9	0
Classroom 320	3	-	-	-	0	0	0	20.9	0
Classroom 323	3	-	-	-	0	0	0	20.9	0
Classroom 327	3	-	-	-	0	0	0	20.9	0
T307 Area	3	-	-	-	0	0	0	20.9	0
Classroom 333	3	-	-	-	0	0	0	20.9	0
Classroom 336	3	-	-	-	0	0	0	20.9	0
Classroom 339	3	-	-	-	0	0	0	20.9	0
Classroom 341	3	-	-	-	0	0	0	20.9	0
Classroom 203A	3	-	-	-	0	0	0	20.9	0
Classroom 205	3	-	-	-	0	0	0	20.9	0
Classroom 210A	3	-	-	-	0	0	0	20.9	0
T204 Area	3	-	-	-	0	0	0	20.9	0
Classroom 204C	3	-	-	-	0	0	0	20.9	0
Classroom 204E	3	-	-	-	0	0	0	20.9	0
Classroom 238	3	-	-	-	0	0	0	20.9	0
Classroom 236	3	-	-	-	0	0	0	20.9	0
Classroom 235	3	-	-	-	0	0	0	20.9	0
Classroom 231	3	-	-	-	0	0	0	20.9	0
T208 Area	3	-	-	-	0	0	0	20.9	0

Classroom 221	3	-	-	-	0	0	0	20.9	0
Classroom 100L	3	-	-	-	0	0	0	20.9	0
Library North End	3	-	-	-	0	0	0	20.9	0
Library South End	3	-	-	-	0	0	0	20.9	0
Classroom 139	3	-	-	-	0	0	0	20.9	0
Hallway at E3	3	-	-	-	0	0	0	20.9	0
Workout room	3	-	-	-	0	0	0	20.9	0
Girls PE Room	3	-	-	-	0	0	0	20.9	0
Boys PE Room	3	-	-	-	0	0	0	20.9	0
Lobby at W10	3	-	-	-	0	0	0	20.9	0
Music Room 131A	3	-	-	-	0	0	0	20.9	0
Custodial room near track	3	-	-	-	0	0	0	20.9	0
Classroom 141	3	-	-	-	0	0	0	20.9	0
Classroom 138B	3	-	-	-	0	0	0	20.9	0
Classroom 102A	3	-	-	-	0	0	0	20.9	0
Classroom 105	3	-	-	-	0	0	0	20.9	0
Classroom 108	3	-	-	-	0	0	0	20.9	0
Classroom 114	3	-	-	-	0	0	0	20.9	0
Outdoors at the South side	3	-	-	-	0	0	0	20.9	0
Classroom 117D	3	-	-	-	0	0	0	20.9	0
Cafeteria East side	3	-	-	-	0	0	0	20.9	0
Cafeteria West side	3	1610	-	-	0	0	0	20.9	0

**APPENDIX B**

**Mold Analytical Data from January 8, 2021**